## FIRE SAFETY CERTIFICATE

No. 18717 USP RF0 2023

07.05.207 Dated: ...

Certified that the SRI VISWA HIGH SCHOOL (Name of the Building or Premises) at D.No.12C, SURVEY No.40/6, ASSESSMENT No.465, GANGASANI AGRAHARAM VILLAGE, RAMAVARAM PANCHAYAT, ANANDAPURAM MANDAL, VISAKHAPATANM - 531173 (Address) comprised of NIL Basement(s) and G+2 (Upper Floors) owned/occupied by SRI VISWA HIGH SCHOOL, UNDER THE MANAGEMENT OF PRAGYNA EDUCATION SOCIETY-VISAKHAPATNAM (Name of the Institution) have complied with the Fire Prevention and Fire Safety Requirements in accordance with Rule of State/UT Fire Service Rules and verified by the Officers concerned of Fire Service on 29-05-2023 (Date of Inspection) in the presence of Sri PERNEEDI SURYANARAYANA, S/o Sri PERNEEDI VEERA BHADRA RAO, D.No.2-67, VENKATESWARA SWAMY GUDI VEEDHI, GONCHALA, H/O PANASAPADU, NAVARA, EAST GODAVARI DIST.-533450 (Name and Addresses of the Manager/Secretary or his Representative) and that the Building / Premises is fit for Occupancy upto Classes XII (X / XII) with effect from 01-06-2023 for a period of 3 (THREE) Years in accordance with Rule and Subject to compliance of specific conditions as appended :-

- 1. This NOC is issued only in the Fire Safety Point of View and this does not give the Applicant a right to claim ownership of the Property.
- All Fire Safety Systems provided shall be maintained in Trim Working Condition at all time.
- 3. All Security/Maintenance Personnel shall be trained on the usage of Fire Equipment provided.
- Fire Drills shall be conducted once in every 3 Months.
- 5. As per Report on Non MSB Inspection Committee, the NOC Committee has scrutinized the Inspection Committee Report along with Proposals and recommended for issuance of No Objection Certificate for Occupancy subject to the following conditions.

(Date of Issue) at ...

\* Strike out whichever is not applicable

(Name & Address of the Instituion)

Signature with Seal

Name

Designation Name & Address of

Department/Office

REGIONAL FIRE OFFICER

REGIONAL FIRE OFFICE, ZONE-I, VISAKHAPATNAM.

REGIONAL FEEL OF LUER Zone-I, Visakhapamam

To SRI VISWA HIGH SCHOOL, D.No.12C, SURVEY No.40/6, ASSESSMENT No.465, GANGASANI AGRAHARAM VILLAGE, RAMAVARAM PANCHAYAT, ANANDAPURAM MANDAL, VISAKHAPATANM – 531173

## ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to (reasons to be recorded).

Name and Designation of the Authorised Signatory)